

**PROJECT DETAILS & LOGOS**

<b>CHECK LIST FOR:</b>				Ref. No: Rev. No: 00 Page : 1 of 2	
<b>Installation &amp; Testing of Fire Fighting Equipment (Fire Hose Reel, Fire Hose Cabinets &amp; Fire Extinguishers)</b>					
SUBCONTRACTOR <input checked="" type="checkbox"/>		CONTRACTOR <input type="checkbox"/>			
SECTION OF WORK: PLUMBING		LOCATION:			
LEVEL:		WIR No.:			
STAGE	ITEM	Checked by		Checked by	Date
		S/C	CONT	Cons.	
SETTING OUT	1. Ensure all shop drawings has been approved by the consultant.				
	2. Check Levels, elevations, distances & sizes of pipes, supports & equipment are as per approved shop drawings & material approvals.				
	3. Ensure all material approvals & material verification records have been approved by the consultant.				
	4. Only trained & experienced personnel shall perform the work.				
CIVIL	5. Ensure civil clearance has been issued prior to start of any installation.				
Installation of Fire Hose Reel & Fire Hose Cabinets	1. Check that bracket supports is placed centrally on the specified location.				
	2. Check that location of the Fire Hose Reel & cabinet are as per the exact location mentioned on the drawings.				
	3. Check for any damages & overall condition of the Fire Hose Reels & cabinets.				
	4. Check all folds of hose are correctly placed over the pins, inside the hose rack.				
	5. Check that nozzle clip is in place & nozzle correctly contained & mounted.				
	6. Check for any damage to couplings & hose section.				
	7. Check that the hose is connected to hose rack nipple. Hose rack nipple shall not be blocked.				
	8. Check if nipple is securely attached to the angle hose valve.				
	9. Check the proper pipe connections to the Fire hose reel.				
	10. Check Fire Hose Reel proper size & attached to the valve.				
	11. Ensure water is supplied to the Valve. Check for any leakage.				
	12. Ensure all Safety Precautions has been check before & after each activity.				

<b>For S/C QA/QC:</b>	<b>Date:</b>	<b>FOR CONTRACTOR QA/QC:</b>	<b>Date:</b>	<b>For CONSULTAN T Rep.:</b>	<b>Date:</b>
<b>Name:</b>	<b>Sign:</b>	<b>Name:</b>	<b>Sign:</b>	<b>Name:</b>	<b>Sign:</b>

**PROJECT DETAILS & LOGOS**

<b>CHECK LIST FOR:</b> <b>Installation &amp; Testing of Fire Fighting Equipment (Fire Hose Reel, Fire Hose Cabinets &amp; Fire Extinguishers)</b>				Ref. No: FM-6012-0084/1	
SUBCONTRACOR <input checked="" type="checkbox"/>		CONTRACTOR <input type="checkbox"/>		Rev. No: 00	
				Page : 2 of 2	
<b>SECTION OF WORK: PLUMBING</b>			<b>LOCATION:</b>		
<b>LEVEL:</b>			<b>WIR No.:</b>		
STAGE	ITEM	Checked by		Checked by	Date
		S/C	CONT	CONS.	
<b>Installation for Fire Extinguishers</b>	13. Check that bracket supports is placed centrally on the specified location intended for the fire extinguishers.				
	14. Check operating instructions on nameplate if legible & facing outward.				
	15. Check safety seals and tampers indicators not broken or missing.				
	16. Check for obvious physical damage, corrosion, leakage or clogged nozzles.				
	17. Check pressure gauge reading or indicator in the operable range or position.				
	18. Check locations of the fire extinguishers as per the approved shop drawings or as per its intended area of use.				
	19. Check the type, size & capacity of fire extinguishers installed.				
	20. Check if nipple is securely attached to the angle hose valve.				
	21. Check if inspection checklist for maintenance & recharging record for the fire extinguisher must be available.				
	22. Fire extinguishers must be located in an accessible area. If fire extinguisher is inside a cabinet, ensure that the cabinet has a breakable glass or easy to open.				
	23. Ensure all safety precautions have been done before & after the installation.				

<b>For S/C</b>	<b>Date:</b>	<b>FOR CONTRACTOR</b>	<b>Date:</b>	<b>For</b>	<b>Date:</b>
<b>QA/QC:</b>		<b>QA/QC:</b>		<b>Consultant</b>	
<b>Name:</b>	<b>Sign:</b>	<b>Name:</b>	<b>Sign:</b>	<b>Rep.:</b>	