

PROJECT NAME & LOGOS

CHECK LIST FOR:				Ref. No: Rev. No: 0 Page : 1 of 2	
Testing & Commissioning of Fire Fighting Equipment (Fire Hose Reel, Fire Hose Cabinets & Fire Extinguishers)					
SUBCONTRACTOR <input checked="" type="checkbox"/>		CONTRACTOR <input type="checkbox"/>			
SECTION OF WORK: PLUMBING		LOCATION:			
LEVEL:		WIR No.:			
STAGE	ITEM	Checked by		Checked by	Date
		S/C	CONT		
SETTING OUT	1. Ensure all shop drawings has been approved by the Consultant.				
	2. Check Levels, elevations, distances & supports & equipment are as per approved shop drawings & material approvals.				
	3. Ensure all material approvals & material verification records have been approved by the Consultant.				
	4. Ensure all installation inspections have been cleared & approved by the Consultant.				
	5. Only trained & experienced personnel shall perform the work.				
CIVIL	1. Ensure civil clearance has been issued prior to start of any installation.				
Testing & Commissioning of Fire Hose Reel, Fire Hose Cabinets	1. Open Fire Hose Cabinet. Check if Fire Hose Cabinet door opens at 180°.				
	2. Check that fire hose rack will swing out of the cabinet for at least 90°.				
	3. Check that the lock is functioning properly. Ensure that the cabinet opens immediately when unlocked.				
	4. Open the metal hose rack. Check if nipple is securely attached to angle hose valve. Ensure nipple is clear of obstruction.				
	5. Unhook the nozzle from the pipe below the Fire Hose Reel. Check the end of nozzle for any tears or damage.				
	6. Check if the reel rotates smoothly by pulling the hose until it fully extends.				
	7. Ensure all safety precautions have been met before & after the testing.				
	8. Open Fire Hose Cabinet. Check if Fire Hose Cabinet door opens at 180°.				

For S/C	Date:	FOR CONTRACTOR	Date:	For CONS	Date:
QA/QC:		QA/QC:		Rep.:	
Name:	Sign:	Name:	Sign:	Name:	Sign:

PROJECT NAME & LOGOS

CHECK LIST FOR:				Ref. No: FM-6012-0084/2	
Testing & Commissioning of Fire Fighting Equipment (Fire Hose Reel, Fire Hose Cabinets & Fire Extinguishers)				Rev. No: 00	
SUBCONTRACOR <input checked="" type="checkbox"/>		CONTRACTOR <input type="checkbox"/>		Page : 2 of 2	
SECTION OF WORK: PLUMBING			LOCATION:		
LEVEL:			ITR No.:		
STAGE	ITEM	Checked by		Checked by	Date
		S/C	CONT	CONS	
Testing & Commissioning of Fire Extinguishers	9. Verify safety pin is intact & no visible signs of any usage.				
	10. Check pressure gauge if fully charged.				
	11. Check that the lock is functioning properly. Ensure that the cabinet opens immediately when unlocked.				
	12. Check if discharge horn & hose move freely & check for any damage.				
	13. The gas cartridge shall be weighed & the weight checked against that marked on the cartridge.				
	14. Test the fire extinguisher by discharging at least 50%.				
	15. Ensure all safety precautions have been met before & after the testing.				

For S/C	Date:	FOR CONTRACTOR	Date:	For CONS	Date:
QA/QC:		QA/QC:		Rep.:	
Name:	Sign:	Name:	Sign:	Name:	Sign: