

CHECK LIST FOR CABLE LAYING AND TERMINATION (CBS).

Contractor :	<input style="width:95%;" type="text"/>	Rev No. : 00 Page: 1 of 1
Consultant :	<input style="width:95%;" type="text"/>	
Sub-Contractor :	<input style="width:95%;" type="text"/>	

Section of Work :	<input style="width:98%;" type="text"/>
Location :	<input style="width:98%;" type="text"/>
Drawing No :	<input style="width:98%;" type="text"/>

Stage	Item	Checked by		Checked by	Date
		sub. Cont.	Cont.	Consultant	
1	Check all the cables, termination accessories make, and type are as per the project approved material submittal and free from damages.				
2	Check cable routing and sleeves for the wall crossing are as per the approved shop drawings				
3	Check the cable size and types are as per the approved Material submittal.				
4	Check cable laid in the cable trays, above false ceiling and cabinets are dressed properly and it is secured with cable tray using suitable cable ties.				
5	Check cables laid above the false ceiling area are supported properly.				
6	Check cable cleats are provided for the surface running at the interval of every 500mm. Where ever it is required				
7	Termination of all the cables are done properly using suitable ferruels				
8	Check the continuity test and meggering of the cables.				
9	Check the tags and identification marks are provided in all the cables and terminals (Temp/ Permanent) for future ref and safety purpose.				
10	Check area is clean and safe after completion of the cable installation work				

MEP Contractor	Main Contractor	Consultant
Date:	Date:	Date:
Name:	Name:	Name:
Sign:	Sign:	Sign: